



Aperture Cut Out Dimensions.

CL300/CL300IN 607 X 607mm

CL600 607 X 1207mm

CL750/CL750IN 607 X 1207mm

Note:

1. 150mm clearance behind the heater is required to enable the installer to slot the heater into the ceiling space, connect power to heater and to rotate heater into the frame.
2. The frame is to be supported by either suitable timber side runners or suspended from above in such manner to enable the frame flange to key with the finished ceiling surface.
3. If using side runners to support the frame, ensure the ceiling cavity depth enables the installing of the heater.



Unit B, 36 Sonter Road
 Riccarton
 Christchurch
 Phone 03 348 0070
 0800 468 356
 Fax 03 348 0067
www.devi.co.nz

Recess frame instruction
 Comfortline low temperature
 radiant heater

Date	Name
19/11/2021	Steve Ross